

Tier 2 MIDEL Transformer DATA SHEET



500kVA Tier 2 - Aluminium Wound MIDEL Filled Distribution Transformer

Specification IEC 60076

Rated Power, Sr 500kVA

50 Hz Rated Frequency, fr

Rated High Voltage, Ur 11000v

Rated Current, Ir 26.24 A

HV Tapping Range +7.5, -5%

Tap Switch, CFVV Off Circuit

Tap Steps 5 x 2.5%

Rated Low Voltage, Ur 415v

Rated Current, Ir 695.60 A

Cooling Method KNAN

Thermal Class A (105°C)

Location Indoor/Outdoor

Coolant Midel 7131

Insulation Level Li75.Ac28 / Ac3

Vector Group Dyn11

CRGO Core Material

Winding Material Aluminium

Temperature Rise Oil/Wdg 60 / 65°C

Load Loss @ 75°C 3900 W

No Load Loss 459 W

Tier 2 EU 548/2014 Ak Ao-10%

Impedance 4.75%

HV Cable Box

3 pole single gland air filled, shroud insulated, suitable for a single multi core cable from below complete with a mild steel gland plate. Compliant with BS EN 50336 and BS 2562. (Excludes necessary glands, lugs and termination kit).

LV Cable Box

4 pole 4 gland air insulated, suitable for single core cables from below, complete with mono block bushing, non-magnetic gland plate. Compliant with BS EN 50336 and BS 2562. (Excludes necessary cables, glands and lugs).

Paint Finish

Painted in accordance with our standard system with a dark admiralty grey finish to BS381C – 632 incorporating corrosion category C4 of ISO 12944.

Neutral Point

A fully rated neutral point provided as standard.

Accessories & Fittings

ENA TS 35-1 terminal height

Oil filler top plate

Oil level indicator

Main lifters

Breather Pipe

Thermometer pocket

Rating and diagram plate with CE and UKCA marks

Oil drain / sampling valve

Stainless steel earth lugs

Jacking points

Skid under base

Accessories Supplied Loose

- 1 x Desiccant breather
- 2 x Tins touch up paint (1x Grey, 1x Yellow)
- 1 x Paint Brush
- 1 x Transformer routine test certificate
- 1 x Certificate of Conformity
- 1 x O&M manual

For standard definitions and references please refer to the latest edition of BS EN 60076-1.

Bowers Electricals Ltd, Heanor Gate Road, Heanor, Derbyshire DE75 7GX

Telephone: 01773 531531 (24 hours)

Fax: 01773 716171

E-mail: enquiries@bowerselec.co.uk www.bowerselec.co.uk