

# Tier 2 MIDEL Transformer **DATA SHEET**



# 800kVA Tier 2 - Aluminium Wound MIDEL Filled Distribution Transformer

**Specification** IEC 60076

Rated Power, Sr 800kVA

Rated Frequency, fr 50 Hz

**Rated High Voltage, Ur** 11000v

Rated Current, Ir 41.99 A

HV Tapping Range +7.5, -5%

**Tap Switch, CFVV** Off Circuit

Tap Steps  $5 \times 2.5\%$ 

Rated Low Voltage, Ur 415v

Rated Current, Ir 1113 A

Cooling Method KNAN

**Thermal Class** A (105°C)

**Location** Indoor/Outdoor

Coolant Midel 7131

**Insulation Level** Li75.Ac28 / Ac3

**Vector Group** Dyn11

Core Material CRGO

Winding Material Aluminium

Temperature Rise Oil/Wdg  $60/65^{\circ}$ C

**Load Loss @ 75°C** 6000 W

No Load Loss 585 W

**Tier 2 EU 548/2014** Ak Ao-10%

Impedance 4.75%

#### **HV Cable Box**

3 pole single gland air filled, shroud insulated, suitable for a single multi core cable from below complete with a mild steel gland plate. Compliant with BS EN 50336 and BS 2562. (Excludes necessary glands, lugs and termination kit).

#### LV Cable Box

4 pole 4 gland air insulated, suitable for single core cables from below, complete with mono block bushing, non-magnetic gland plate. Compliant with BS EN 50336 and BS 2562. (Excludes necessary cables, glands and lugs).

#### **Paint Finish**

Painted in accordance with our standard system with a dark admiralty grey finish to BS381C – 632 incorporating corrosion category C4 of ISO 12944.

#### **Neutral Point**

A fully rated neutral point provided as standard.

## **Accessories & Fittings**

ENA TS 35-1 terminal height

Oil filler top plate

Oil level indicator

Main lifters

Breather Pipe

Thermometer pocket

Rating and diagram plate with CE and UKCA marks

Oil drain / sampling valve

Stainless steel earth lugs

Jacking points

Skid under base

## **Accessories Supplied Loose**

- 1 x Desiccant breather
- 2 x Tins touch up paint (1x Grey, 1x Yellow)
- 1 x Paint Brush
- 1 x Transformer routine test certificate
- 1 x Certificate of Conformity
- 1 x O&M manual

For standard definitions and references please refer to the latest edition of BS EN 60076-1.

Bowers Electricals Ltd, Heanor Gate Road, Heanor, Derbyshire DE75 7GX

Telephone: 01773 531531 (24 hours) E-mail: enquiries@bowerselec.co.uk Fax: 01773 716171 www.bowerselec.co.uk

Registered at the above address in England Company No: 1955004 VAT Ref: 4163613